

Questions & Answers

#1

1. I am writing to submit a clarification request regarding the referenced RFB for generator servicing. To support accurate and consistent pricing across all responding vendors, would the County be able to provide a list of the generators & ATS / switch gear included within the three-year scope of work? If available, the following information would be helpful:

- Make and model
- Generator / ATS size-rating
- Fuel type (diesel, natural gas, propane, gasoline, etc.)
- Current run hours
- Mobile or permanent / stationary

Answer: Please see the attached list of HCSO generators.

The list of generators provided with the solicitation reflects the Hillsborough County Sheriff's Office's current known inventory at the time of bid issuance. However, this inventory may change during the term of the contract, and additional generators or different generator brands may be added or replaced as operational needs require.

Bidders are advised that pricing should not be contingent upon specific generator brands. Pricing is expected to be structured based on generator capacity (kilowatt size), as the intent of this solicitation is to allow flexibility for servicing generators of varying manufacturers provided they meet the required specifications.

Accordingly, bidders should submit pricing by kW size category rather than by brand to ensure consistency and applicability throughout the contract term.

2. For planning and response-time considerations, could the County advise whether generator locations are geographically concentrated or if certain sites are located more than approximately 25 miles apart, or alternatively provide a general reference point for distance calculations?

Answer: All HCSO generator sites are within 18 miles of the centrally located Sheriff's Operations Center (SOC) with two exceptions. The generators located at the Walter C. Heinrich Practical Training Site (WCHPTS) in Lithia, is approximately 30 miles from the SOC. The generator located at District IV is approximately 25 miles from the SOC.

3. In order to provide the most accurate (and thus lowest possible) bid possible for this job, it would greatly assist our estimating efforts if we could obtain a list of the generators within this project scope.?

Answer: Please see Question #1 for this information.

HCSO Site	Mobile/ Permanent	Generator Information		Model	ATS Information		Fuel Information	
		Model	kW				Total (gal)	Fuel Type (Diesel, Propane)
78 St Comm Tower	Permanent	Kohler 100REZGD	100	Unavailable			3000	Propane
78 St Comm Tower -Trailer	Mobile	Kohler 100RE0ZIN	100	Unavailable			200	Diesel
Aviation	Permanent	Tradewinds TP150E	150	Unavailable			1042	Diesel
Brandon Comm Tower #1	Permanent	Tradewinds TGM-60	60	Unavailable			1000	Propane
Canine Training Facility	Permanent	Tradewinds TP350E-UL60T3G	350	Eaton ATC300			500	Diesel
Bullfrog Comm Tower #1	Permanent	Tradewinds TGM-60	60	Unavailable			1500	Propane
Bullfrog Comm Tower #2	Permanent	Tradewinds TGM-60	60	Unavailable			1500	Propane
Cork Knight Comm Tower	Permanent	Kohler 100REZGD	100	Unavailable			2000	Propane
District 1	Permanent	Tradewinds TP150E	150	Thompson TS873A0800A1CM5EKCAA			3042	Diesel
District 3	Permanent	Tradewinds TP150E	150	Thompson TS873A0800A1CG5AKCAA			1542	Diesel
District 4	Permanent	Tradewinds TP130	150	Thompson TS873A0400A1CY5			3050	Diesel
District 4 Comm Tower #1	Permanent	Kohler 100REZGD	95	Unavailable			2000	Propane
District 4 Comm Tower #2	Permanent	Tradewinds TGM-60	60	Unavailable			2000	Propane
FRW Fuel Site - Secondary Generator	Permanent	Tradewinds TJ30UL	30	N/A			120	Diesel
FS-10 Comm Tower #1	Permanent	Onan GGFE-4959219	47	Unavailable			1500	Propane
FS-10 Comm Tower #2	Permanent	Tradewinds TGM-60	60	Unavailable			1500	Propane
FS-20 Comm Tower	Permanent	Kohler KG100	100	Unavailable			2000	Propane
Gunn Hwy Comm Tower	Permanent	Kohler 100REZGD	100	Unavailable			2000	Propane
Hanna Comm Tower	Permanent	Tradewinds TGM-100	100	Unavailable			1000	Propane
Himes Comm Tower	Permanent	Kohler 50REZGB	50	Unavailable			1000	Propane
Hurrah Comm Tower #1	Permanent	Tradewinds TGM-60	60	Unavailable			1750	Propane
Orient Road Warehouse	Permanent	Tradewinds TP60	60	Unavailable			500	Diesel
Pinebrooke 1 - Community Outreach	Permanent	Tradewinds TP300E	300	Unavailable			500	Diesel
Pinebrooke 1 - Community Outreach	Permanent	Tradewinds TP200E-UL60L70T3G	200	Unavailable			500	Diesel
Pinebrooke 1 - Training	Permanent	Kohler 500REOZVB	500	ASCO 7000 D07ATSB30100C50F			1500	Diesel
Pinebrooke 2 - SID	Permanent	Tradewinds TP350E-UL60T3G	350	Marathon-Thompson TS883A1600A1CE5EQQAA			2000	Diesel
Pinebrooke 3 - District V	Permanent	Tradewinds TP200E-UL60L70T3	200	Marathon-Thompson TS873A0800A1CE5EKCAA			2084	Diesel
SOC - Tampa #1	Permanent	Kohler 900REOZDB	900	None			1600	Diesel
SOC - Tampa #2	Permanent	Kohler 900REOZDB	900	Kohler Power Systems GLS-566341-0225			1600	Diesel
Pinebrooke 3 - HR	Permanent	Kohler 135ROZJ	135	ASCO A300380091XC			1000	Diesel
Pinebrooke 3 - ISD	Permanent	Tradewinds TP150-UL60L70T3G	150	Thompson TS873A0800A1CM5DKCAA			2084	Diesel
Pinebrooke 4 - CID	Permanent	Tradewinds TP500E-UL60T2G	500	Thompson TS553A2000B1AE5LRQAA			2550	Diesel
Pinebrooke 4 - DNA Lab	Permanent	Tradewinds TP200E-UL60L70T3G	200	Unavailable			500	Diesel
Pinebrooke 5 - #1	Permanent	Cummins 500DFED-2276	500	Unavailable			2500	Diesel
Pinebrooke 5 - #2	Permanent	Cummins 500DFED-2276	500	Unavailable			2500	Diesel
Pinecrest Comm Tower #1	Permanent	Kohler 100REZGD	100	Unavailable			2000	Propane
Pinecrest Comm Tower #2	Permanent	Tradewinds TGM-100	100	Unavailable			2000	Propane
Plant City Comm Tower #1	Permanent	Onan GGFE-4959219	47	Unavailable			1500	Propane
Plant City Comm Tower #2	Permanent	Tradewinds TGM-60	60	Unavailable			1500	Propane
Portable Unit - Evidence Backup	Permanent	Tradewinds TD40	55	N/A			120	Diesel
Health and Wellness Clinic	Permanent	Guardian/Generac 0043903	15	Unavailable			250	Propane
RS Trailer Mount Comm Tower	Mobile	Tradewinds TP100E	100	Unavailable			200	Diesel
SOC - Ybor - Annex	Permanent	Kohler 350ROZ71	350	ASCO 940			2000	Diesel
SOC - Ybor - Freddie Solomon Annex	Permanent	Tradewinds TJ200T33	200	Thompson TS873A0800B1A			500	Diesel
SOC - Ybor - Main	Permanent	Kohler 600R02D71	600	ASCO 940			2000	Diesel
Taylor Rd I Comm Tower	Permanent	Tradewinds TGM-60	60	Unavailable			1500	Propane
Taylor Rd I Comm Tower - Spare	Permanent	Tradewinds TGM-60	60	Unavailable			1500	Propane
Taylor Rd II Comm Tower	Permanent	Cummins C50 N6	50	Unavailable			1500	Propane
WCHPTS - Administration	Permanent	Tradewinds TJ56E	56	Unavailable			295	Diesel
WCHPTS - Comm Shed	Permanent	Cummins Onan DKAЕ3374085	20	Unavailable			150	Diesel
WCHPTS - Maintenance	Permanent	Tradewinds TP56E-UL60T	56	Unavailable			150	Diesel
WCHPTS - New Armory	Permanent	Tradewinds T20E-UL60T41G	20	Unavailable			110	Diesel
WCHPTS - North Water Plant	Permanent	Tradewinds T20E-UL60T41G	20	Unavailable			110	Diesel
WCHPTS - Pavilion	Permanent	Tradewinds TP150E	150	Eaton 6D32360G45			500	Diesel
WCHPTS - School House	Permanent	Tradewinds TP150E	150	Eaton 6D32360G45			500	Diesel
WCHPTS - South Water Plant	Permanent	Tradewinds TP20E-UL60T41G	20	Unavailable			110	Diesel
Wimauma Comm Tower	Permanent	Kohler KG100	100	Unavailable			2000	Propane