

**HILLSBOROUGH COUNTY SHERIFF'S OFFICE
FINANCIAL SERVICES DIVISION
PURCHASING UNIT
QUESTIONS AND ANSWERS FOR
RFP NO. 2021-004 DIESEL GENERATOR TANK REPLACEMENT
AS OF APRIL, 15 2021 3:00 PM**

Question#1: *The "FD" boxes that are on E-101 and E-102 are not production items and would need to be custom made. The manufacturer is requesting the application type, cover type and hub sizes needed to fabricate the custom boxes unless there is a pre-existing alternative that is available.*

Answer #1: The FD boxes shall be sized as follows: "NEMA 4 watertight, cast aluminum with gasketed covers and threaded hubs." Hub sizes and locations shall be responsibility of the Contractor.